

Номера портов контроллеров ОВЕН для библиотеки SysLibCom

ПЛК100, 150, 154

COM0 – RS485

COM1 – RS232

COM4 – RS232-Debug

ПЛК110, 160

COM0 – RS485-1

COM1 – RS232

COM2 – RS485-2

COM4 – RS232-Debug

ПЛК110 [M02], 160 [M02]

COM0 – RS485-1

COM1 – RS232

COM2 – RS485-2

COM4 – RS232-Debug

ПЛК63

COM0 – RS485

COM1 – RS232

COM4 – RS232-Debug

ПЛК73

COM0 – RS1

COM1 – RS2